



PARIYARAM MEDICAL COLLEGE HOSPITAL

SAHAKARANA HRUDAYALAYA

Department of Cardio Vascular Sciences

(A unit of Kerala State Co-operative Hospital Complex & Centre for Advanced Medical Services Ltd, No.4368, Pariyaram)

QUOTATION NOTICE

Notification Ref.	P1/1107/2014/SH/17-18
Date	01/02/2018
Closing date	09/02/2018 4 PM
Department	Sahakarana Hrudayalaya
Equipment	10 KVA UPS

Specification

- Supply Installation Testing and Commissioning of 10 KVA online double conversion UPS of true sine wave with IGBT technology.
- Unity power factor on input and THD <5%
- Wide input voltage range (for medical equipment load) with output galvanic isolation transformer,
- Auto and manual maintenance bypass.
- Parallel redundant configuration.
- Single phase 230/240V, 50 Hz output and three phase 415V/400V,50 Hz, 4 wire input,
- Generator compatible and shall be suitable to existing 20 Nos, 12 Volt Sealed Maintenance Free battery.

Preferred make: VERTIV, Nuemarc, APC - Libert super 400D or equivalent model

BUY BACK : Buy Back with 10 KVA IGA TECH Make 3 Phase/1 Phase UPS

Director

(S/d)